

**CONDUIT AND MANHOLES**  
**PRECAUTIONS**

**1. GENERAL**

1.001 This addendum supplements Section 622-100-010.

1.002 It is issued to comply with Company requirements and California General Order No. 128.

(b) Proposals for joint occupancy with power facilities in utility tunnels shall be reviewed by the Chief Engineer's Department.

7.01.1 Existing cases of joint occupancy with power facilities:

**7. JOINT OCCUPANCY OF MANHOLES WITH POWER FACILITIES**

The following change applies to Part 7.

(a) 7.01 - replaced

7.01 Joint occupancy with power facilities is restricted as follows:

(a) New Construction - joint occupancy of any underground chamber (except tunnels and permanent cable trenches) with power facilities of any voltage is not permitted.

(a) Where joint occupancy exists and re-inforcement or rearrangement of telephone facilities is required, the final arrangement shall eliminate the joint occupancy.

(b) The precautions listed in 7.02 shall be followed whenever it is necessary to work in a jointly occupied manhole or handhole.