

TROUBLE TICKETER FRAME
AUTOMATIC NUMBER IDENTIFICATION-TYPE B
EQUIPMENT DESIGN REQUIREMENTS
NO. 1 CROSSBAR, PANEL AND STEP-BY-STEP SYSTEMS

1. GENERAL

SCOPE

1.01 This specification, together with the supplementary information listed herein, covers the equipment design requirements for the framework, equipment, and circuits to be used in the engineering, manufacture, and installation of the trouble ticketer (TTKT) frame used as part of the Automatic Number Identification—Type B (ANI-B) equipment in decoder panel, No. 1 crossbar, and No. 1, 350A, and 355A step-by-step offices.

1.02 This specification is reissued:

- (a) To add requirements for the 9-foot 0-inch high trouble ticketer frame for use in step-by-step offices.
- (b) To replace the existing fuse panel (J93403B) with a modular type fuse panel (J93403P).
- (c) To provide equipment for operation with a Centralized Status Alarm and Control System (CSACS).

CAPACITY

1.03 An 11-foot 6-inch high TTKT frame is arranged for use with a maximum of ten outputers, two identifiers, and 70 outputer connector trunk subgroups in each of three identifier groups and for permanent signal identification on a maximum of 600 permanent signal holding trunks. It may be equipped to lock up a connection for trouble tracing purposes. This feature is arranged for a maximum of 107 ANI trunk frames in three identifier groups.

1.04 A 9-foot 0-inch high TTKT frame is arranged for use with a maximum of six outputers, two identifiers, and 70 outputer connector trunk subgroups in one identifier group and for permanent signal identification on a maximum of 180 permanent signal holding trunks. It may be equipped to lock-up a connection for trouble tracing purposes. This feature is arranged for a maximum of 70 ANI trunk frames.

DESCRIPTION

1.05 The TTKT frame uses a single-bay bulb-angle framework 11 feet 6 inches high and 2 feet 5/8 inch long with a 10 inch wide guardrail or a single-bay bulb-angle framework 9 feet 0 inches high and 2 feet 5/8 inch long with a 10-inch or 12-inch guardrail. It is arranged for 2- by 23-inch mounting plates.

1.06 The equipment of the TTKT frame is shown in Fig. 1 and Fig. 2. The fuse panel and the various groups of mountings identified as units are separately manufactured surface-wired units. These, and the remaining items of equipment illustrated, are interwired with a frame local cable.

1.07 The main purpose of the TTKT frame is to record available pertinent data on calls encountering trouble in the ANI equipment. Each such record is printed by a Teletype Corporation 1A message ticketer on the frame and consists of a 2-1/2 by 5 inch paper ticket with a single row of characters recording such information as type of call; trunk, outputer, identifier, identifier group, and calling station numbers; outputer and identifier progress; and time of day.

1.08 In panel and crossbar offices, which automatically route permanent signals to holding trunks, the ANI equipment and the TTKT frame are used

J93403, ISSUE 7
SECTION 814-600-150, 815-408-150, 816-206-150




Fig. 1—Common Systems Trouble Ticketer Frame ANI

to identify the station connected to such a trunk. This eliminates the need for tracing connections from the trunk back through the switching network to determine the line involved.

1.09 The TTKT frame also accommodates outpulser and identifier usage lamps, jacks for making individual outpulsers and identifiers busy, jacks for making specific identifiers busy to specific

outpulsers, registers for recording identifier and




Fig. 2—Trouble Ticketer Frame

outpulser failures, miscellaneous trouble and alarm lamps, and control jacks and keys.

1.10 The preferred location of the TTKT frame is in the test or maintenance center, adjacent to the ANI-B outpulser-identifier-trunk test frame. Where this is impracticable, these frames should be located near each other and near associated outpulser frames.

1.11 As ANI-B equipment will frequently be located in available space in existing offices, the frames may be located adjacent to others with guardrails of different width. This necessitates provision of appropriate junction details.

J93403, ISSUE 7
ISS 7, SECTION 814-600-150, 815-408-150, 816-206-150

SUBDIVISIONS OF EQUIPMENT AND DETAILED INDEX

WE J drawings should be ordered by referring to the prefix and base number and requesting the current dash (—) number.

EQUIPMENT CODE	RATING OF UNIT	TITLE	EQUIPMENT DRAWING	CIRCUIT DRAWING
J93403A	AT&TCo Std	Trouble Ticketer Frame — 11'-6" High	J93403A-()	SD-95816-01 SD-95817-01 SD-95823-01 SD-95827-01
J93403C	AT&TCo Std	Permanent Signal Identification Unit	J93403C-()	SD-95817-01
J93403D	AT&TCo Std	Connector Control Unit	J93403D-()	SD-95816-01 SD-95823-01
J93403E	AT&TCo Std	Timer Unit	J93403E-()	SD-95816-01
J93403F	AT&TCo Std	Register Unit	J93403F-()	SD-95823-01
J93403G	AT&TCo Std	Permanent Signal Holding Trunk Jack Unit	J93403G-()	SD-95817-01
J93403H	AT&TCo Std	Control Unit	J93403H-()	SD-95816-01 SD-95823-01
J93403J	AT&TCo Std	Progress and Register Unit	J93403J-()	SD-95816-01
J93403K	AT&TCo Std	Miscellaneous Register Unit	J93403K-()	SD-95816-01 SD-95823-01
J93403L	AT&TCo Std	Trunk and Number Register Unit	J93403L-()	SD-95816-01
J93403M	AT&TCo Std	Terminating Marker Unit	J93403M-()	SD-95816-01 SD-95823-01
J93403N	AT&TCo Std	Trouble Ticketer Frame — 9'-0" High	J93403N-()	SD-95816-01 SD-95817-01 SD-95823-01
J93403P	AT&TCo Std	Fuse Panel	J93403P-()	SD-95823-01

J93403, ISSUE 7
SECTION 814-600-150, 815-408-150, 816-206-150

Circuit Schematic Index

CIRCUIT DRAWING	J93403 EQPT CODE
SD-95816-01	A,D,E,H,J,K,L,M,N
SD-95817-01	A,C,G,N
SD-95823-01	A,B,D,F,H,K,M,N,P
SD-95827-01	A

2. SUPPLEMENTARY INFORMATION

800-600-000—List of General Equipment Requirements
Sections

814-000-000—Step-by-Step Systems Index

815-000-000—Panel Systems Index

816-000-000—No. 1 Crossbar System Index

Floor Plan Data—Section 7.1, Sheet 51

KS-9784—Ticket Paper

Current Drain Data:

SD-21300-01—Panel Offices—Battery Cutoff (No
Current Drain Data Available for
Panel Offices—Ground Cutoff)

SD-25000-02—No. 1 Crossbar

SD-31359-02—No. 1 Step-by-Step

3. DRAWINGS

For additional drawings forming part of this
specification, see listings under Subdivisions of
Equipment and Detailed Index.

Keysheets

SD-21300-01—Panel System—Battery Cutoff Relay
Offices

SD-21680-01—Panel System—Ground Cutoff Relay
Office

SD-25000-01—No. 1 Crossbar System
SD-31359-01—Step-by-Step Systems—No. 1
SD-31364-01—Step-by-Step Systems—No. 350A
SD-31780-01—Step-by-Step Systems—No. 355A

Equipment

ED-95131-01—Fuse Panel Assembly
ED-91710-73—Bulb-Angle Frame Assembly
ED-25529-70—Guardrail Junctions
ED-94848-73—Bulb-Angle Frame Assembly
ED-91837-71—Bulb-Angle Frame Assembly

Wiring and Cabling

ED-25346-14 } Method of Running Power
ED-25346-15 } Feeders—No. 1 Crossbar
ED-27114-01—Table of Wire Gauges and Types of
Insulation—No. 1 Crossbar
ED-31351-()—Method of Running Power
Feeders—Step-by-Step Systems
ED-95094-()—TTKT Frame—Switchboard Cabling
Details
ED-99431-10—Method of Running Power Feeders—
Common Systems
SD-80728-01—Battery Distributing Circuit—Step-by-
Step Systems

4. EQUIPMENT

J93403A—AT&T Co Std—Trouble Ticketer Frame

Equipment—J93403A-()

List 1—Framework, assembly, wiring, and common
equipment for one trouble ticketer frame
for use with step-by-step office, or panel
and/or crossbar office ANI equipment.
(See Notes A and B.)

J93403, ISSUE 7
ISS 7, SECTION 814-600-150, 815-408-150, 816-206-150

	WIRE	EQUIP	NOTES
TTKT Ckt, SD-95816-01:			
Fig. 1	1	1	C
Fig. 2	3	0	
Fig. 4	1	0	
PS Ident Ckt, SD-95817-01:			
Fig. 1 With W and X Options, Fig. 2 & Fig. 4 With V Option Each	1	0	
TTKT Fr Misc Ckt, SD-95823-01:			
Fig. 1 With H Option (Lamp Only), Less T and S App	1	1	
Fig. 2	6	0	
Fig. 3	21	0	
Fig. 4 & 5, Each	1	0	
Fig. 7	3	0	
Fig. 8, With G, F, E, A, ZA, and ZB Options	1	0	
Fig. 9	1	0	
OSC Ckt, SD-95827-01:			
Fig. 1 & 2	1	0	

List 2—Apparatus per SD-95823-01, Fig. 1, T apparatus only, required in addition to list 1 to equip one TTKT frame for use in panel and/or crossbar offices.

List 3—Apparatus per SD-95823-01, Fig. 1, S apparatus only, required in addition to list 1 to equip one TTKT frame for use in step-by-step offices.

List 4—Apparatus per SD-95823-01, Fig. 7, lamps and jack only, required in addition to list 1 for each identifier group with which the TTKT frame is to operate.

List 5—Apparatus per SD-95823-01, Fig. 2, I-B jack and ID- lamp only, required in addition to list 1 for each identifier frame with which the TTKT frame is to operate.

List 6—Apparatus per SD-95823-01, Fig. 3, jacks and lamp only, required in addition to list 1 for each outputer with which the TTKT frame is to operate. (See Note F.)

List 7—Apparatus per SD-95823-01, Fig. 4, lamps and key only, required in addition to list 1 to equip one TTKT frame with the trunk lockup feature.

List 8—Apparatus per SD-95817-01, Fig. 2, TO

and TPD lamps only, required in addition to list 1 to equip one TTKT frame for permanent signal identification. (See Note E.)

List 9—Apparatus per SD-95823-01, Fig. 9, required in addition to list 1 for each AIOD translator when automatic identification of outward-dialed PBX calls is provided in one or more identifier groups (maximum 3).

List 10—Apparatus and wiring per SD-95823-01, Fig. 4, B option, required in addition to list 1 for installations serving in excess of 48 trunk subgroups.

List 11—Equipment per SD-95823-01, two Fig. 11, required in addition to list 12 for each J93403M terminating marker unit associated with the trouble ticketer frame

List 12—Equipment per SD-95823-01, Fig. 12, lamp only, required in addition to list 1 when trouble ticketer frame is arranged to operate with outputers and/or No. 1 crossbar terminating markers to record calls to a particular line for calling line identification.

List 13—Apparatus per SD-95817-01, Fig. 1, X option only, required in addition to list 8 for identifying coin charge troubles on coin lines associated with first identifier group in No. 1 crossbar offices or panel offices.

List 14—Apparatus per SD-95817-01, Fig. 4, V option only, required in addition to list 8 for identifying coin charge troubles on coin lines associated with second identifier group in No. 1 crossbar offices or panel offices.

List 15—Apparatus per SD-95817-01, Fig. 1, W option only, required in addition to list 8 for identifying coin charge troubles on coin lines associated with third identifier group in No. 1 crossbar offices or panel offices.

List 16—Apparatus and wiring required in addition to list 1 for the first identifier group when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZH option of SD-95823-01, one Fig. 1, two Fig. 2, and ten Fig. 3.

List 17—Apparatus and wiring required in addition to list 16 for the second or third identifier group when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZH option of SD-95823-01, two Fig. 2, and ten Fig. 3. (Max 2 list

J93403, ISSUE 7
SECTION 814-600-150, 815-408-150, 816-206-150

17.)

List 19—Apparatus and wiring required in addition to list 12 when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZL option of SD-95823-01, Fig. 12.

Notes

A. Units as follows are ordered as required:

J93403C, Maximum 1
J93403D, Maximum 3
J93403F, Maximum 3
J93403G, Maximum 10
J95108D, Maximum 1
J93403M, Maximum 3

One each of the following units is always required:

J93403E
J93403H
J93403J
J93403K
J93403L
J93403P

These units are ordered separately and are mounted on the frame and connected in the shop and shown in Fig. 1. Other components are part of J93403A. J93403C, J93403G, and J95108D are required for permanent signal identification in step-by-step or panel and/or crossbar offices. Units per J93403D and J93403F, one each, are required per identifier group with which the frame is to operate.

- B. The frame local cable, furnished with list 1, contains that wiring for the specified figures which is not furnished as surface wiring in the coded units. The local cable includes all options.
- C. Equipment included in list 1 for SD-95816-01 consists of that apparatus per Fig. 1 which is not part of the coded units.
- D. The small amount of frame wiring required for the permanent signal holding trunk jacks is furnished on a job basis as loose wiring.

- E. The B ground required for the permanent signal holding trunk jacks consists of a No. 6 ground lead on the frame upright. This ground lead is furnished as part of list 8.
- F. For installations requiring more than seven outpulsers the additional 248A jack mounting with the necessary jacks and lamps per Fig. 3 shall be located on a job basis. Where the OITT and TTKT frames are located adjacently it is recommended that the ED-92250-70, G1 writing shelf location on the OITT frame be utilized.

J93403C—AT&TCo Std—Permanent Signal Identification Unit

Equipment—J93403C-()

List 1—Assembly, wiring, and common equipment per SD-95817-01, Fig. 1, for one permanent signal identification unit.

List 3—Apparatus and wiring per SD-95817-01, Fig. 1, Z option only, or Fig. 4, required in addition to list 1 for each of the second and third identifier groups with which the permanent signal identification unit is to operate.

J93403D—AT&TCo Std—Connector Control Unit

Equipment—J93403D-()

List 1—Framework, equipment, assembly, and wiring per SD-95823-01, Fig. 7, apparatus as shown, less L option, for one connector control unit. (See 5.01.)

List 2—Apparatus and wiring per SD-95816-01, Fig. 2, required in addition to list 1 for each outpulser in the identifier group with which the connector control unit is to operate.

List 3—Apparatus and wiring per SD-95823-01, Fig. 2, AF- and I-B relays only, required in addition to list 1 for each identifier in the identifier group with which the connector control unit is to operate.

List 4—Apparatus and wiring per SD-95823-01, Fig. 7, L option only, required in addition to list 1 to equip one connector control unit with the trunk lockup feature.

List 5—Apparatus and wiring per SD-95816-01, Fig. 3, required in addition to list 1 to equip one connector control unit for use

in buildings having more than one identifier group.

- List 6**—Apparatus and wiring required in addition to list 1 when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZH option of SD-95823-01, Fig. 7.

J93403E—AT&TCo Std—Timer Unit

Equipment—J93403E-()

- List 1**—Equipment, assembly, and wiring per SD-95816-01, Fig. 1, for one timer unit. (See 5.01.)

- List 2**—Apparatus and wiring required in addition to list 1 when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZP option of SD-95816-01, Fig. 1.

J93403F—AT&TCo Std—Register Unit

Equipment—J93403F-()

- List 1**—Equipment, assembly, and wiring per SD-95823-01, Fig. 7, 2TF and TC registers only, for one register unit.

- List 2**—Apparatus and wiring per SD-95823-01, Fig. 2, 1AF- and 1TF- registers and 1AF- resistor only, required in addition to list 1 for each identifier in the identifier group with which the register unit is to operate.

- List 3**—Apparatus and wiring per SD-95823-01, Fig. 3, OPF- register only, required in addition to list 1 for each outputer in the identifier group with which the register unit is operated. (Max 7, see Note B.)

- List 4**—Apparatus and wiring per SD-95823-01, Fig. 1, H option, SCF message register only, required in addition to list 1 when a service call failure register is specified. (See Note A.)

Notes

- A. List 4, when specified, shall be provided on the first unit only.
- B. See frame list for more than 7 outputers.

J93403G—AT&TCo Std—Permanent Signal Holding Trunk Jack Unit

Equipment—J93403G-()

- List 1**—Equipment, assembly, and wiring per SD-95817-01, 10 Fig. 3, for one permanent signal holding trunk jack unit equipped with jacks for the first ten trunks, 0 to 9, on the unit. (See Notes A and B.)

- List 2**—Apparatus and wiring per SD-95817-01, 10 Fig. 3, required in addition to list 1 for each additional ten consecutive trunks on one permanent signal holding trunk jack unit. (See Note B.)

- List 3**—Equipment and assembly per SD-95817-01, Fig. 2, PS cord and plug only, required in addition to list 1 for the first permanent signal holding trunk jack unit, to provide an identification cord. (See Note C.)

Notes

- A. Y wiring when furnished with lists 1 and 2 consists of strapping between the jack springs and B ground leads for each five jacks, long enough to connect to the No. 6 ground lead on the frame upright. The large number of ground leads is required for current drain purposes.
- B. The sleeves of all jacks are strapped together; this strapping to be cut to group the jacks by associated identifier groups and connected by loose wiring to A ground or associated GP-relay, as required.
- C. List 3 includes a cord fastener detail, an unwired No. 239A jack, jack mounting modifications, and stamping.

J93403H—AT&TCo Std—Control Unit

Equipment—J93403H-()

- List 1**—Framework, equipment, assembly, and wiring per SD-95816-01, Fig. 1, and SD-95823-01, Fig. 1, less R option, for one control unit. (See 5.01.)

- List 2**—Apparatus and wiring per SD-95823-01, Fig. 5, V option, FA relay only, required in addition to list 1 to equip one control unit for use with step-by-step offices.

- List 3**—Apparatus and wiring per SD-95823-01,

J93403, ISSUE 7
SECTION 814-600-150, 815-408-150, 816-206-150

Fig. 4, less X option, required in addition to list 1 to equip one control unit with the trunk lockup feature. (See 5.01.)

- List 4**—Apparatus and wiring per SD-95823-01, Fig. 4, X option only, required in addition to lists 1 and 3 to arrange for trunk lockup with more than 23 ANI trunk frames.
- List 5**—Apparatus and wiring per SD-95823-01, Fig. 1, R option only, required in addition to list 1 to equip one control unit for alarm transfer with tone identification.
- List 6**—Apparatus and wiring per SD-95823-01, Fig. 1, B option, required in addition to list 1 for offices serving in excess of 48 subgroups.
- List 7**—Apparatus and wiring required in addition to list 1 when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZP option of SD-95816-01, Fig. 1.

J93403J—AT&TCo Std—Progress and Register Unit

Equipment—J93403J-()

- List 1**—Framework, equipment, assembly, and wiring per SD-95816-01, Fig. 1, less K, M, and N options, for one progress and register unit. (See 5.01.)
- List 2**—Apparatus and wiring per SD-95816-01, Fig. 1, K, M, or N option only, required in addition to list 1 in one progress and register unit when any associated identifier group includes outpulser 1, 3, or 5.
- List 3**—Apparatus and wiring per SD-95823-01, Fig. 8, G option, required in addition to list 1 to arrange for trunk lockup with more than 35 ANI trunk frames.
- List 4**—Apparatus and wiring per SD-95823-01, Fig. 8, F option, required in addition to list 3 to arrange for trunk lockup with more than 47 ANI trunk frames.
- List 5**—Apparatus and wiring per SD-95823-01, Fig. 8, E option, required in addition to list 4 to arrange for trunk lockup with more than 59 ANI trunk frames.
- List 6**—Apparatus and wiring per SD-95823-01, Fig. 8, A option, required in addition to list 5 to arrange for trunk lockup with more than 71 ANI trunk frames.
- List 7**—Apparatus and wiring per SD-95823-01, Fig. 8, ZA option, required in addition to list 6 to arrange for trunk lockup with

more than 83 ANI trunk frames.

- List 8**—Apparatus and wiring per SD-95823-01, Fig. 8, ZB option, required in addition to list 7 to arrange for trunk lockup with more than 95 ANI trunk frames.
- List 9**—Apparatus and wiring per SD-95816-01, Fig. 1, ZC option, required in addition to list 1 when any associated identifier group includes outpulser 7.
- List 10**—Apparatus and wiring per SD-95816-01, Fig. 1, ZD option, required in addition to list 1 when any associated identifier group includes outpulser 9.

J93403K—AT&TCo Std—Miscellaneous Register Unit

Equipment—J93403K-()

- List 1**—Framework, equipment, assembly, and wiring per SD-95816-01, Fig. 1, less R, T, and V options, for one miscellaneous register unit. (See 5.01.)
- List 2**—Apparatus and wiring per SD-95816-01, Fig. 1, T option only, required in addition to list 1 to equip one miscellaneous register unit for use with step-by-step offices.
- List 3**—Apparatus and wiring per SD-95816-01, Fig. 1, V option only, required in addition to list 1 to equip one miscellaneous register unit for use with panel offices serving 2-party lines.
- List 4**—Apparatus and wiring per SD-95816-01, Fig. 1, R option only, required in addition to list 1 to equip one miscellaneous register unit for permanent signal identification.
- List 5**—Apparatus and wiring per SD-95816-01, Fig. 1, G option only, required in addition to list 1 for use when operating with one or more identifier groups arranged for automatic identification of outward dialing (AIOD) from PBX stations.
- List 6**—Apparatus and wiring per SD-95816-01, Fig. 1, E option only, required in addition to list 1 for use when any identifier group contains a seventh office unit, or when the office index requires the use of digit 6 for automatic identification of outward dialing (AIOD) from PBX stations.
- List 7**—Apparatus and wiring per SD-95816-01, Fig. 1, B option only, required in addition to list 6 when the office index requires the use of digits 7 and 8 for automatic identification of outward dialing (AIOD)

from PBX stations.

List 8—Apparatus and wiring per SD-95816-01, Fig. 1, A option only, required in addition to list 5 for use when more than one PBX-AIOD translator is served.

List 9—Apparatus and wiring per SD-95816-01, Fig. 4, required in addition to list 1 for operation with outpulsers to record calling line identification.

List 10—Apparatus and wiring per SD-95816-01, Fig. 6, required in addition to list 1 in No. 1 crossbar offices for operation with terminating markers to record calling line identification.

List 11—Apparatus and wiring per SD-95823-01, Fig. 12, relay only, required in addition to list 1 when trouble ticketer frame is arranged to operate with outpulsers and/or No. 1 crossbar terminating markers to record the calling line identification on calls to a particular line.

J93403L—AT&TCo Std—Trunk and Number Register Unit

Equipment—J93403L-()

List 1—Equipment, assembly, and wiring per SD-95816-01, Fig. 1, for one trunk and number register unit. (See 5.01 and Note A.)

List 2—Apparatus and wiring per SD-95816-01, Fig. 1, ZN option, required in addition to list 1 when an identifier group serves more than 48 trunk subgroups.

Note

A. Furnish ZI wiring only when operation with outpulsers arranged to outpulse called numbers to an automatic intercept center is required.

J93403M—AT&TCo Std—Terminating Marker Unit

Equipment—J93403M-()

List 1—Assembly, wiring, and common equipment for one terminating marker unit arranged to serve two marker groups of up to ten terminating markers, each for use in No. 1 crossbar offices for recording calls terminated to a particular line. (See Note

A.)

	WIRE	EQUIP	NOTES
TTKT Ckt, SD-95816-01: Fig. 5	20	0	
Misc Ckt, SD-95823-01: Fig. 10	2	1	

List 2—Equipment per SD-95823-01, Fig. 10, required in addition to list 1 for second marker group on unit.

List 3—Equipment per SD-95816-01, Fig. 5, required in addition to list 1 for each terminating marker associated with a group.

Note

A. A maximum of three J93403M units may be provided for use with a J93403A trouble ticketer frame. These units are to be mounted on a miscellaneous relay rack.

J93403N—AT&TCo Std—Trouble Ticketer Frame 9 Foot 0 Inch High Frames for Use in SXS Offices

Equipment—J93403N-()

List 1—Framework, assembly, wiring, and common equipment for one trouble ticketer frame without 5-inch cable rack. (See Notes A and B.)

J93403, ISSUE 7
SECTION 814-600-150, 815-408-150, 816-206-150

	WIRE	EQUIP	NOTES
TTKT Ckt, SD-95816-01:			
Fig. 1	1	1	C
Fig. 2 and 4	2	0	
Perm Sig Ident Ckt, SD-95817-01:			
Fig. 1 and 2	1	0	
Fig. 3	0	0	D,E
Misc Ckt, SD-95823-01:			
Fig. 1 with S option	1	1	
Fig. 4 and 5	1	0	
Fig. 2	2	0	
Fig. 3	6	0	
Fig. 7 (Lamps and Jacks Only)	1	1	
Fig. 8 with A, E, F, G, ZA, and ZB options	1	0	
Fig. 9	1	0	
OSC Ckt, SD-95827-01:			
Fig. 1 and 2	1	0	

List 2—Framework, assembly, wiring, and common equipment for one trouble ticketer frame with 5-inch cable rack. (See Notes A and B.)

	WIRE	EQUIP	NOTES
TTKT Ckt, SD-95816-01:			
Fig. 1	1	1	C
Fig. 2 and 4	2	0	
Perm Sig Ident Ckt, SD-95817-01:			
Fig. 1 and 2	1	0	
Fig. 3	0	0	D,E
Misc Ckt, SD-95823-01:			
Fig. 1 with S Option	1	1	
Fig. 4 and 5	1	0	
Fig. 2	2	0	
Fig. 3	6	0	
Fig. 7 (Lamps and Jacks Only)	1	1	
Fig. 8 with A, E, F, G, ZA, and ZB Options	1	0	
Fig. 9	1	0	
OSC Ckt, SD-95827-01:			
Fig. 1 and 2	1	0	

List 3—Apparatus per SD-95823-01, Fig. 2, I-B jack and ID- lamp only, required in addition to list 1 for each identifier frame with which the TTKT frame is to operate.

List 4—Apparatus per SD-95823-01, Fig. 3, jacks and lamp only required in addition to list 1 for each outpulser with which the TTKT frame is to operate.

List 5—Apparatus per SD-95823-01, Fig. 4, lamps and key only required in addition to list 1 to equip one TTKT frame with the trunk lock-up feature.

List 6—Apparatus per SD-95817-01, Fig. 2 (TO) and (TPD) lamps only, required in addition to list 1 to equip one TTKT frame for permanent signal identification. (See Note E.)

List 7—Apparatus per SD-95823-01, Fig. 8, lamps and jacks only, required in addition to list 1 for each AIOD translator when automatic identification of outward-dialed PBX calls is provided.

List 8—Apparatus and wiring per SD-95823-01, Fig. 4, B option, required in addition to list 1 for installations serving in excess of 48 trunk subgroups.

List 9—Equipment per SD-95823-01, Fig. 12, lamp only, required in addition to list 1 when TTKT frame is arranged to record calls to a particular line for calling line identification.

List 10—Apparatus and wiring required in addition to list 1 or 2 for one identifier group when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZH option of SD-95823-01, Fig. 1, two Fig. 2, and ten Fig. 3.

List 13—Apparatus and wiring required in addition to list 9 when connection to a Centralized Status Alarm and Control System (CSACS) is required per ZL option of SD-95823-01, Fig. 12.

Notes

A. Units per J93403C, J93403D, J93403E, J93403F, J93403G, J93403H, J93403J, J93403K, J93403L, J93403P, and J95108D are ordered separately and are mounted on the frame and connected in the shop as shown in Fig. 2. Other components are part of J93403N.

B. The frame local cable furnished with list 1 or 2, contains the wiring for the specified figures which is not furnished as surface wiring in the coded units. The local cable includes all options.

J93403, ISSUE 7
ISS 7, SECTION 814-600-150, 815-408-150, 816-206-150

- C. Equipment included in list 1 or 2 for SD-95816-01 includes apparatus per Fig. 1 or 2 which is not part of the coded units.
- D. The small amount of frame wiring required for the permanent signal holding trunk jacks is furnished on a job basis as loose wiring.
- E. The B ground required for the permanent signal holding trunk jacks consists of a No. 6 ground lead on the frame upright. This ground lead is furnished as part of list 6.

J93403P—AT&T Co Std—Trouble Ticketer Frame Fuse Panel

Equipment—J93403P- ()

List 1—Assembly, wiring, and equipment for one trouble ticketer frame fuse panel arranged for step-by-step offices. (See Note A.)

	WIRE	EQUIP	NOTES
Misc Ckt, SD-95823-01:			
Alm. Ckt Fig. 5 With V			
Option Less FA Rel	1	1	
Ckt Fuses Fig. 6			
(Max 34 Fuse Pos)		30	

List 2—Apparatus and wiring per SD-95823-01, W option is required in addition to list 1 to arrange the fuse panel for No. 1 crossbar or panel offices. (See Note B.)

Notes

- A. Fusing for the Oscillator Circuit SD-95827-01, Fig. 1 is provided in list 1.
- B. When apparatus and wiring per SD-95823-01, W option is required, apparatus and wiring per SD-95823-01, V option must be removed.

5. GENERAL NOTES

Equipment

- 5.01** The apparatus included in various coded units is not completely identifiable by circuit

apparatus figures. It is prescribed for each by the pertinent lists on the associated J drawings.

Wiring and Cabling

5.02 The TTKT frame is arranged for solderless-wrapped connections. ED-27114-01 covers the types and gauges of all wire and cable used in the manufacture and installation of the TTKT frame.

5.03 All coded units covered by this specification are surface wired. Interwiring between them and to other components on the frame is included in the frame local cable.

5.04 Power feeders are furnished for the ANI frames in accordance with the applicable listed drawings. The battery distribution system should be connected by a No. 6 drop lead to the fuse panel on the TTKT frame. The ground feeder for each row of frames bonded by top angle ground bars should conform to the arrangements of the particular system to which these frames are connected.

5.05 The code numbers of the switchboard cables used in cabling the TTKT frame are shown on the switchboard cabling drawing ED-95094-10. This drawing and the CAD figures on the circuits identify the leads involved and their destinations.

List of A&M Only and Mfr Disc. Equipment

EQUIPMENT	RATING	DETAILS	REPLACING EQUIPMENT
		LAST SHOWN IN ISSUE	
J93403B	Mfr Disc.	6	J93403P

The above equipment has been replaced as indicated. Where A&M Only items appear, the issue numbers shown are those of the issue in which the rating was first applied.

Bell Telephone Laboratories, Incorporated

Dept 5245