

ERECTING POLES AND STUBS

GENERAL

NOTES CONCERNING THIS ADDENDUM

This addendum is being issued to provide additional information for the placing of guards on poles.

The cross-reference "See Addendum" should be marked in the main section to indicate the following:

- Paragraph 8.01 - Replaced in Part
- Paragraph 9.01 - Supplemented

8. HUB GUARDS

8.01 Where poles must be so located that hub guards are desirable for protection of the timber, place guards as shown in the sketch in 8.01 of main Section (Cancel paragraph preceding drawing). Type S guards are bent on a radius of 5-1/2 inches while type L have a radius of 7-1/2 inches.

9. GUARDS FOR CREOSOTED POLES

9.01 The measurement 2 ft. 2 in., shown in the sketch for locating B Pole Step Mounting, does not apply in this Area and reference to Sections covering Stepping Poles - General, and Stepping Poles - Locating Line Steps, should be made.