

Copyright, 1957, by
The Pac. Tel. & Tel. Co.

BELL SYSTEM PRACTICES
Outside Plant Construction
and Maintenance

ADDENDUM G41.902
Issue B, Nov., 1957-N

MAIN CONDUIT

LAYING SOAPSTONE CONDUIT

This addendum to Section G41.902, Issue B, is reissued to substitute Type CT Soapstone Conduit and CT Couplings for Type B Soapstone Conduit and B Couplings. Type B Soapstone is discontinued and Type CT Soapstone is now standard in this Area. Reference to Type B Soapstone Conduit and Couplings throughout the main section should be corrected to read Type CT Soapstone Conduit and Type CT Couplings. Type CT Conduit has a regular octagonal exterior and a 3-1/2-inch bore. It is placed in the same manner as shown for Type B Conduit. Type CT Couplings must be ordered separately.

Write "See Addendum" at Part 2 and Paragraphs 1.01, 1.03 and 7.01 of the main section.

2. MATERIAL

Conduit, Soapstone
Type CT, Dwg. L-4618

Furnished in 4-foot
lengths

Coupling, Soapstone
Type CT, Dwg. L-4619

For joining Type CT
Soapstone Conduit