

MANHOLES

GENERAL

NOTES CONCERNING THIS ADDENDUM

This addendum provides measurements to be used in determining vertical racking space in manholes due to the additional space required by the use of large splice cases. With the introduction of shorter splice cases an extra 3 inches in splicing bays is no longer required and this addendum is reissued to delete requirements in Issue A. Manholes with dimensions shown in the main section are again standard.

Paragraph 5.01(c) is replaced and should be marked "See Addendum".

5. HEADROOM

5.01(c) Where either single or double racking is to be employed, use the following vertical spacing between cable centers:

Staggered Splices	7-1/2 inches*
Non-staggered Splices	9 inches*

* Loading splices should generally be racked at 10-1/2 inches on centers vertically.